



Meter Test Certification Form

A Division of National Meter & Automation, Inc.
 7220 S Fraser St
 Centennial, CO 80112
 Telephone: (303) 339-9100
 Website: www.nmaai.com

Utility: Treatment Technology	
Addr 1: P.O. Box 668	
Addr 2: 28577 Buffalo Park Rd	Test date: 08/28/2014
City: Evergreen	Time in:
State: CO	Date out:
Zip code: 80439	Time out:

Serial number: 13432644 **Note:** ~~████████~~ Cabrini Blvd - ~~██████████~~ - ~~██████████~~

Manufacture	Manu Mdl	Type Meter	Size	Test	Flow	Gal/CuFt	Start Reading	End Reading	Usage	Actual Flow	Percentage	AWWA STD	Pass/Fail
Badger Meter, Inc.	RCDL25	DP	3/8" x 3/4"	Min	0.25	Gallon	53501.00	53511.00	10.00	9.98	100.2004	95 - 101	Pass
Badger Meter, Inc.	RCDL25	DP	3/8" x 3/4"	Mid	2.00	Gallon	53511.00	53520.60	9.60	9.50	101.0526	98.5 - 101.5	Pass
Badger Meter, Inc.	RCDL25	DP	3/8" x 3/4"	Max	15.00	Gallon	53520.60	53621.30	100.70	101.20	99.5059	98.5 - 101.5	Pass

Serial number: 13432811 **Note:** ~~████████~~ Cabrini Blvd - ~~██████████~~

Manufacture	Manu Mdl	Type Meter	Size	Test	Flow	Gal/CuFt	Start Reading	End Reading	Usage	Actual Flow	Percentage	AWWA STD	Pass/Fail
Badger Meter, Inc.	RCDL25	DP	3/8" x 3/4"	Min	0.25	Gallon	6267.40	6277.40	10.00	9.98	100.2004	95 - 101	Pass
Badger Meter, Inc.	RCDL25	DP	3/8" x 3/4"	Mid	2.00	Gallon	6277.40	6287.00	9.60	9.50	101.0526	98.5 - 101.5	Pass
Badger Meter, Inc.	RCDL25	DP	3/8" x 3/4"	Max	15.00	Gallon	6287.00	6387.60	100.60	101.20	99.4071	98.5 - 101.5	Pass

The above listed meters have been tested in accordance with the provision established by AWWA New Meter Accuracy Standards and as Certified by the State of Colorado's Weights and Measures Division. The results listed accurately reflect current meter condition(s). All Flow Rates are in gallons.

Tester: Wylie Beal
Signature: Wylie Beal
Date: 8-28-14